FIRE INSPECTOR'S INTER-OFFICE CORRESPONDENCE

TO:

Genaro Argenio, Planning Board Chairman

FROM:

Wm. Horton, Asst. Fire Inspector

SUBJECT: PB-07-14

Nowicki Sub.

SBL: 57-1-88.22 & 88.23

DATE:

May 18, 2007

Fire Prevention Reference Number: FPS-07-013

A review of the above referenced subdivision plan has been conducted and is approved with the following being noted:

* Note: The Nowicki Subdivision is approved however all driveways will have to be at minimum 20' wide throughout and must be impervious and able to withstand the weight of fire apparatus. (120 PSI).